CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. Page 1 of 1 7135-1130:233

CATEGORY: Speakers

LISTEE: Honeywell International Inc. 1500 W. Dundee Road, Arlington Heights, IL 60004-1472

Contact: Bob Hodgson (847) 797-4403 Fax (847) 797-3664

DESIGN: Models XLS964-1A-4RR, -4RW, and -8RW, XLS965-1A-4RR, -4RW, -8RW and -8SW

> Round or Square Baffle Speakers. Suffix "W" indicates white color and "R" indicate red color. Refer to listee's data sheet for detailed product description and operational

considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and

ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as speakers for use with separately listed compatible fire alarm control units.

Speakers are provided with a strobe for the hearing impaired. For indoor use only.

Speakers may be round or square in design.

If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation signal (for total evacuation) in accordance with NFPA 72, 1999 Edition is required, the appliance must be used with a fire alarm control unit that can generate the temporal pattern signal. Refer to

listee's Installation Instruction Manual for details.

XLF: 7135-1591:169

09-12-03KK



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

JUNE 22, 2004 Listing Expires June 30, 2005 Date Issued:

DIANE K. AREND, Senior Deputy Authorized By:

Program Manager